

SMARTER ENERGY SOLUTION

Preventive Maintenance Solar System



Customer Name :	Khun Jeab	Maintenance :	MA	Date :	4 April 2025
Solar Panel		Inverter			
Brand	Model	Capacity	Install	Brand	Model
Exicom	Cx480 TC	10 kWp.	92 Panels	Solix	SE-GR3P10K
		S/N 1805020236270034			

Before Preventive Maintenance Solar System

Solar Panels	Operating Voltage / Current					Time	Inspection		Remark
String 1	11 Panels	Vmp 350.4	Vdc	Voc 412.7	Vdc	Isc 3.10 A.	13:00	✓ Pass	Not Pass
String 2	11 Panels	Vmp 352.9	Vdc	Voc 419.3	Vdc	Isc 2.86 A.	:	✓ Pass	Not Pass
String 3	Panels	Vmp	Vdc	Voc	Vdc	Isc A.	:	Pass	Not Pass
String 4	Panels	Vmp	Vdc	Voc	Vdc	Isc A.	:	Pass	Not Pass
String 5	Panels	Vmp	Vdc	Voc	Vdc	Isc A.	:	Pass	Not Pass
String 6	Panels	Vmp	Vdc	Voc	Vdc	Isc A.	:	Pass	Not Pass
String 7	Panels	Vmp	Vdc	Voc	Vdc	Isc A.	:	Pass	Not Pass
String 8	Panels	Vmp	Vdc	Voc	Vdc	Isc A.	:	Pass	Not Pass
String 9	Panels	Vmp	Vdc	Voc	Vdc	Isc A.	:	Pass	Not Pass
String 10	Panels	Vmp	Vdc	Voc	Vdc	Isc A.	:	Pass	Not Pass
String 11	Panels	Vmp	Vdc	Voc	Vdc	Isc A.	:	Pass	Not Pass
String 12	Panels	Vmp	Vdc	Voc	Vdc	Isc A.	:	Pass	Not Pass

After Preventive Maintenance Solar System

Solar Panels	Operating Voltage / Current					Time	Inspection		Remark
String 1	11 Panels	Vmp 399.8	Vdc	Voc 435.6	Vdc	Isc 3.17 A.	13:45	✓ Pass	Not Pass
String 2	11 Panels	Vmp 394.2	Vdc	Voc 435.2	Vdc	Isc 3.02 A.	:	✓ Pass	Not Pass
String 3	Panels	Vmp	Vdc	Voc	Vdc	Isc A.	:	Pass	Not Pass
String 4	Panels	Vmp	Vdc	Voc	Vdc	Isc A.	:	Pass	Not Pass
String 5	Panels	Vmp	Vdc	Voc	Vdc	Isc A.	:	Pass	Not Pass
String 6	Panels	Vmp	Vdc	Voc	Vdc	Isc A.	:	Pass	Not Pass
String 7	Panels	Vmp	Vdc	Voc	Vdc	Isc A.	:	Pass	Not Pass
String 8	Panels	Vmp	Vdc	Voc	Vdc	Isc A.	:	Pass	Not Pass
String 9	Panels	Vmp	Vdc	Voc	Vdc	Isc A.	:	Pass	Not Pass
String 10	Panels	Vmp	Vdc	Voc	Vdc	Isc A.	:	Pass	Not Pass
String 11	Panels	Vmp	Vdc	Voc	Vdc	Isc A.	:	Pass	Not Pass
String 12	Panels	Vmp	Vdc	Voc	Vdc	Isc A.	:	Pass	Not Pass

Inverter Inspection

Device	Field Measured Readings		Readings from Inverter Display		Readings from Smarter Meter		Field Measured Back Up	
Inverter	AC Line Voltage		AC Line Voltage		AC Line Voltage		AC Line Voltage	
	Phase L1 to Grd :	224.1 Vac.	Phase L1 to Grd :	222.9 Vac.	Phase L1 to Grd :	225.1 Vac.	Phase L1 to Grd :	Vac.
	Phase L2 to Grd :	227.2 Vac.	Phase L2 to Grd :	227.2 Vac.	Phase L2 to Grd :	227.7 Vac.	Phase L2 to Grd :	Vac.
	Phase L3 to Grd :	225.1 Vac.	Phase L3 to Grd :	228.4 Vac.	Phase L3 to Grd :	225.8 Vac.	Phase L3 to Grd :	Vac.
	AC Line Current		AC Line Current		AC Line Current			
	Phase L1 to Grd :	3.15 A.	Phase L1 to Grd :	3.21 A.	Phase L1 to Grd :	14.40 A.		
	Phase L2 to Grd :	2.96 A.	Phase L2 to Grd :	3.20 A.	Phase L2 to Grd :	7.80 A.		
	Phase L3 to Grd :	2.99 A.	Phase L3 to Grd :	3.22 A.	Phase L3 to Grd :	28.20 A.		

Comment :

Inspection By :

(Buntharn Libnuy) Project Engineer

Date : / /

SMARTER ENERGY SOLUTION

Electrical Room Inspection



Device	Ambient Temp	Temperature						Remark
Inverter	39.7 °C	Inside :	47.8 °C	Outside :	42.2 °C	Heatsync :	50.2 °C	
AC Cabinet	38.6 °C	MCB Breaker :	38.7 °C	RCCB Breaker :	38.7 °C	AC SPD :	39.6 °C	
			40 A.		40 A.		3 Phase	
		Smart Meter :	39.9 °C	AC Terminal	37.8 °C	CT Ratio :	./ A.	
			3 Phase	AC Cable :	6 Sq.m.	Meter Ratio :	A.	
		String No.	DC Fuse	DC Breaker	DC SPD	MC4 Connector		
DC Cabinet	38.4 °C	String 1	37.8 °C	37.8 °C	39.1 °C	36.7 °C		
		String 2	38.2 °C	38.4 °C	37.9 °C	36.6 °C		
		String 3	°C	°C	°C	°C		
		String 4	°C	°C	°C	°C		
		String 5	°C	°C	°C	°C		
		String 6	°C	°C	°C	°C		
		String 7	°C	°C	°C	°C		
		String 8	°C	°C	°C	°C		
		String 9	°C	°C	°C	°C		
		String 10	°C	°C	°C	°C		
		String 11	°C	°C	°C	°C		
		String 12	°C	°C	°C	°C		
EE Room	38.7 °C	AC Cable :	20 Sq.m.	Main Breaker :	80 A.	MCCB Feed :	A.	
		Wireway :	36.5 °C	MDB / LC :	39.7 °C		°C	

Comment : _____

Inspection By :

(Bunharn Libnoy)Project Engineer

Date : ____/____/____