

SMARTER ENERGY SOLUTION

Preventive Maintenance Solar System



Customer Name : Pungila Plot 3				Maintenance : MA		Date : 11 September 2025	
Solar Panel				Inverter			
Brand	Model	Capacity	Install	Brand	Model	S/N	
Sonnax	Srx-D60 HNP-480W	20 kWp.	60 Panels	Solis	SB-EN3P20K-A	1033160248180013	

Before Preventive Maintenance Solar System

Solar Panels	Operating Voltage / Current					Time	Inspection		Remark
String 1	Panels	Vmp	Vdc	Voc	Isc		Pass	Not Pass	
String 2	Panels	Vmp	Vdc	Voc	Isc		Pass	Not Pass	
String 3	Panels	Vmp	Vdc	Voc	Isc		Pass	Not Pass	
String 4	Panels	Vmp	Vdc	Voc	Isc		Pass	Not Pass	
String 5	Panels	Vmp	Vdc	Voc	Isc		Pass	Not Pass	
String 6	Panels	Vmp	Vdc	Voc	Isc		Pass	Not Pass	
String 7	Panels	Vmp	Vdc	Voc	Isc		Pass	Not Pass	
String 8	Panels	Vmp	Vdc	Voc	Isc		Pass	Not Pass	
String 9	Panels	Vmp	Vdc	Voc	Isc		Pass	Not Pass	
String 10	Panels	Vmp	Vdc	Voc	Isc		Pass	Not Pass	
String 11	Panels	Vmp	Vdc	Voc	Isc		Pass	Not Pass	
String 12	Panels	Vmp	Vdc	Voc	Isc		Pass	Not Pass	

After Preventive Maintenance Solar System

Solar Panels	Operating Voltage / Current					Time	Inspection		Remark
String 1	Panels	Vmp	Vdc	Voc	Isc		Pass	Not Pass	
String 2	Panels	Vmp	Vdc	Voc	Isc		Pass	Not Pass	
String 3	Panels	Vmp	Vdc	Voc	Isc		Pass	Not Pass	
String 4	Panels	Vmp	Vdc	Voc	Isc		Pass	Not Pass	
String 5	Panels	Vmp	Vdc	Voc	Isc		Pass	Not Pass	
String 6	Panels	Vmp	Vdc	Voc	Isc		Pass	Not Pass	
String 7	Panels	Vmp	Vdc	Voc	Isc		Pass	Not Pass	
String 8	Panels	Vmp	Vdc	Voc	Isc		Pass	Not Pass	
String 9	Panels	Vmp	Vdc	Voc	Isc		Pass	Not Pass	
String 10	Panels	Vmp	Vdc	Voc	Isc		Pass	Not Pass	
String 11	Panels	Vmp	Vdc	Voc	Isc		Pass	Not Pass	
String 12	Panels	Vmp	Vdc	Voc	Isc		Pass	Not Pass	

Inverter Inspection

Device	Field Measured Readings		Readings from Inverter Display		Readings from Smarter Meter		Field Measured Back Up	
Inverter	AC Line Voltage		AC Line Voltage		AC Line Voltage		AC Line Voltage	
	Phase L1 to Grd :	232.8 Vac.	Phase L1 to Grd :	Vac.	Phase L1 to Grd :	232.6 Vac.	Phase L1 to Grd :	Vac.
	Phase L2 to Grd :	231.9 Vac.	Phase L2 to Grd :	Vac.	Phase L2 to Grd :	232.1 Vac.	Phase L2 to Grd :	Vac.
	Phase L3 to Grd :	233.0 Vac.	Phase L3 to Grd :	Vac.	Phase L3 to Grd :	233.2 Vac.	Phase L3 to Grd :	Vac.
	AC Line Current		AC Line Current		AC Line Current			
	Phase L1 to Grd :	14.30 A.	Phase L1 to Grd :	A.	Phase L1 to Grd :	14.70 A.	Phase L1 to Grd :	A.
	Phase L2 to Grd :	14.60 A.	Phase L2 to Grd :	A.	Phase L2 to Grd :	14.20 A.	Phase L2 to Grd :	A.
	Phase L3 to Grd :	13.80 A.	Phase L3 to Grd :	A.	Phase L3 to Grd :	13.40 A.	Phase L3 to Grd :	A.

Comment :

Inspection By :

(Bunhann Library) Project Engineer

Date : / /