

SMARTER ENERGY SOLUTION

Preventive Maintenance Solar System



Customer Name : Shambala Investor 1 Maintenance : MA Date : 12 December 2024

Solar Panel				Inverter		
Brand	Model	Capacity	Install	Brand	Model	S/N
		Kwp.	Panels			

Before Preventive Maintenance Solar System

Solar Panels	Operating Voltage / Current				Time	Inspection		Remark
String 1	Panels	Voc <u>517.4</u> Vdc	Vmp <u>442.3</u> Vdc	Isc <u>3.00</u> A.	<u>13 : 30</u>	☒ Pass	☐ Not Pass	
String 2	Panels	Voc <u>518.1</u> Vdc	Vmp <u>440.6</u> Vdc	Isc <u>2.95</u> A.	:	☒ Pass	☐ Not Pass	
String 3	Panels	Voc _____ Vdc	Vmp _____ Vdc	Isc _____ A.	:	☐ Pass	☐ Not Pass	
String 4	Panels	Voc _____ Vdc	Vmp _____ Vdc	Isc _____ A.	:	☐ Pass	☐ Not Pass	
String 5	Panels	Voc _____ Vdc	Vmp _____ Vdc	Isc _____ A.	:	☐ Pass	☐ Not Pass	
String 6	Panels	Voc _____ Vdc	Vmp _____ Vdc	Isc _____ A.	:	☐ Pass	☐ Not Pass	
String 7	Panels	Voc _____ Vdc	Vmp _____ Vdc	Isc _____ A.	:	☐ Pass	☐ Not Pass	
String 8	Panels	Voc _____ Vdc	Vmp _____ Vdc	Isc _____ A.	:	☐ Pass	☐ Not Pass	
String 9	Panels	Voc _____ Vdc	Vmp _____ Vdc	Isc _____ A.	:	☐ Pass	☐ Not Pass	
String 10	Panels	Voc _____ Vdc	Vmp _____ Vdc	Isc _____ A.	:	☐ Pass	☐ Not Pass	
String 11	Panels	Voc _____ Vdc	Vmp _____ Vdc	Isc _____ A.	:	☐ Pass	☐ Not Pass	
String 12	Panels	Voc _____ Vdc	Vmp _____ Vdc	Isc _____ A.	:	☐ Pass	☐ Not Pass	

After Preventive Maintenance Solar System

Solar Panels	Operating Voltage / Current				Time	Inspection		Remark
String 1	Panels	Voc <u>524.8</u> Vdc	Vmp <u>439.2</u> Vdc	Isc <u>2.98</u> A.	<u>19:00</u>	☒ Pass	☐ Not Pass	
String 2	Panels	Voc <u>523.4</u> Vdc	Vmp <u>428.2</u> Vdc	Isc <u>3.01</u> A.	:	☒ Pass	☐ Not Pass	
String 3	Panels	Voc _____ Vdc	Vmp _____ Vdc	Isc _____ A.	:	☐ Pass	☐ Not Pass	
String 4	Panels	Voc _____ Vdc	Vmp _____ Vdc	Isc _____ A.	:	☐ Pass	☐ Not Pass	
String 5	Panels	Voc _____ Vdc	Vmp _____ Vdc	Isc _____ A.	:	☐ Pass	☐ Not Pass	
String 6	Panels	Voc _____ Vdc	Vmp _____ Vdc	Isc _____ A.	:	☐ Pass	☐ Not Pass	
String 7	Panels	Voc _____ Vdc	Vmp _____ Vdc	Isc _____ A.	:	☐ Pass	☐ Not Pass	
String 8	Panels	Voc _____ Vdc	Vmp _____ Vdc	Isc _____ A.	:	☐ Pass	☐ Not Pass	
String 9	Panels	Voc _____ Vdc	Vmp _____ Vdc	Isc _____ A.	:	☐ Pass	☐ Not Pass	
String 10	Panels	Voc _____ Vdc	Vmp _____ Vdc	Isc _____ A.	:	☐ Pass	☐ Not Pass	
String 11	Panels	Voc _____ Vdc	Vmp _____ Vdc	Isc _____ A.	:	☐ Pass	☐ Not Pass	
String 12	Panels	Voc _____ Vdc	Vmp _____ Vdc	Isc _____ A.	:	☐ Pass	☐ Not Pass	

Inverter Inspection				Remark
Device	Readings from Smarter Meter	Readings from Inverter Display	Field Measured Readings	
Inverter	AC Line Voltage		AC Line Voltage	<u>back up voltage</u> L1 <u>231.7</u> Vac L2 <u>232.2</u> Vac L3 <u>232.3</u> Vac
	Phase L1 to Grd : _____ Vac	Phase L1 to Grd : _____ Vac	Phase L1 to Grd : <u>231.1</u> Vac	
	Phase L2 to Grd : _____ Vac	Phase L2 to Grd : _____ Vac	Phase L2 to Grd : <u>231.3</u> Vac	
	Phase L3 to Grd : _____ Vac	Phase L3 to Grd : _____ Vac	Phase L3 to Grd : <u>231.9</u> Vac	
	AC Line Current		AC Line Current	
	Phase L1 to Grd : _____ A	Phase L1 to Grd : _____ A	Phase L1 to Grd : <u>1.81</u> A	
	Phase L2 to Grd : _____ A	Phase L2 to Grd : _____ A	Phase L2 to Grd : <u>6.68</u> A	
	Phase L3 to Grd : _____ A	Phase L3 to Grd : _____ A	Phase L3 to Grd : <u>7.97</u> A	

Comment : _____

SMARTER ENERGY SOLUTION

Electrical Room Inspection



Customer Name :				Date :		
Solar Panel				Inverter		
Brand	Model	Capacity	Install	Brand	Model	S/N
		Kwp.	Panels			

Device	Ambient Temperature	Temperature				Remark
Inverter	43.3 °C	Inside : 47.3 °C	Outside : 44.6 °C	Heatsync : 49.1 °C		
AC Cabinet	36.7 °C	MCB Breaker : 32 A.	RCCB Breaker : _____ A.	AC SPD : 3 Phase		
		AC Cable : 10 Sq.m.	Smart Meter : 38.4 °C	CT Ratio : _____ A.		
		AC Terminal : 37.2 °C	Phase Meter Ratio : _____ A.			
		String No.	DC Fuse	DC Breaker	DC SPD	MC4 Connector
DC Cabinet 1	36.4 °C	String 1	36.7 °C	36.7 °C	36.6 °C	37.9 °C
		String 2	36.7 °C	36.8 °C	37.2 °C	37.8 °C
		String 3	_____ °C	_____ °C	_____ °C	_____ °C
		String 4	_____ °C	_____ °C	_____ °C	_____ °C
EE Room	36.7 °C	AC Cable : 25 Sq.m.	Main Breaker : 100 A.	MCCB Feed : _____ A.		
		Wireway : 37.9 °C	MDB / LC : 38.1 °C	_____ °C		

Comment : _____

Inspection By : _____

(Bunharn Libnoy)
Project Engineer

Date : ____ / ____ / ____

SMARTER ENERGY SOLUTION

Preventive Maintenance Solar System



Customer Name : Shambala Inverter 2 Maintenance : MA Date : 12 December 2024

Solar Panel				Inverter		
Brand	Model	Capacity	Install	Brand	Model	S/N
		Kwp.	Panels			

Before Preventive Maintenance Solar System

Solar Panels	Operating Voltage / Current				Time	Inspection		Remark
String 1	Panels	Voc <u>608.4</u>	Vdc	Vmp <u>488.7</u>	Vdc	Isc <u>2.97</u>	A.	<u>13:30</u> ☒ Pass ☐ Not Pass
String 2	Panels	Voc <u>609.4</u>	Vdc	Vmp <u>505.2</u>	Vdc	Isc <u>2.69</u>	A.	☒ Pass ☐ Not Pass
String 3	Panels	Voc	Vdc	Vmp	Vdc	Isc	A.	☐ Pass ☐ Not Pass
String 4	Panels	Voc	Vdc	Vmp	Vdc	Isc	A.	☐ Pass ☐ Not Pass
String 5	Panels	Voc	Vdc	Vmp	Vdc	Isc	A.	☐ Pass ☐ Not Pass
String 6	Panels	Voc	Vdc	Vmp	Vdc	Isc	A.	☐ Pass ☐ Not Pass
String 7	Panels	Voc	Vdc	Vmp	Vdc	Isc	A.	☐ Pass ☐ Not Pass
String 8	Panels	Voc	Vdc	Vmp	Vdc	Isc	A.	☐ Pass ☐ Not Pass
String 9	Panels	Voc	Vdc	Vmp	Vdc	Isc	A.	☐ Pass ☐ Not Pass
String 10	Panels	Voc	Vdc	Vmp	Vdc	Isc	A.	☐ Pass ☐ Not Pass
String 11	Panels	Voc	Vdc	Vmp	Vdc	Isc	A.	☐ Pass ☐ Not Pass
String 12	Panels	Voc	Vdc	Vmp	Vdc	Isc	A.	☐ Pass ☐ Not Pass

After Preventive Maintenance Solar System

Solar Panels	Operating Voltage / Current				Time	Inspection		Remark
String 1	Panels	Voc <u>617.0</u>	Vdc	Vmp <u>510.4</u>	Vdc	Isc <u>2.92</u>	A.	<u>13:00</u> ☒ Pass ☐ Not Pass
String 2	Panels	Voc <u>621.0</u>	Vdc	Vmp <u>527.2</u>	Vdc	Isc <u>2.83</u>	A.	<u>15:00</u> ☒ Pass ☐ Not Pass
String 3	Panels	Voc	Vdc	Vmp	Vdc	Isc	A.	☐ Pass ☐ Not Pass
String 4	Panels	Voc	Vdc	Vmp	Vdc	Isc	A.	☐ Pass ☐ Not Pass
String 5	Panels	Voc	Vdc	Vmp	Vdc	Isc	A.	☐ Pass ☐ Not Pass
String 6	Panels	Voc	Vdc	Vmp	Vdc	Isc	A.	☐ Pass ☐ Not Pass
String 7	Panels	Voc	Vdc	Vmp	Vdc	Isc	A.	☐ Pass ☐ Not Pass
String 8	Panels	Voc	Vdc	Vmp	Vdc	Isc	A.	☐ Pass ☐ Not Pass
String 9	Panels	Voc	Vdc	Vmp	Vdc	Isc	A.	☐ Pass ☐ Not Pass
String 10	Panels	Voc	Vdc	Vmp	Vdc	Isc	A.	☐ Pass ☐ Not Pass
String 11	Panels	Voc	Vdc	Vmp	Vdc	Isc	A.	☐ Pass ☐ Not Pass
String 12	Panels	Voc	Vdc	Vmp	Vdc	Isc	A.	☐ Pass ☐ Not Pass

Inverter Inspection				Remark
Device	Readings from Smarter Meter	Readings from Inverter Display	Field Measured Readings	
Inverter	AC Line Voltage		AC Line Voltage	
	Phase L1 to Grd : _____ Vac	Phase L1 to Grd : _____ Vac	Phase L1 to Grd : <u>231.2</u> Vac	
	Phase L2 to Grd : _____ Vac	Phase L2 to Grd : _____ Vac	Phase L2 to Grd : <u>231.4</u> Vac	
	Phase L3 to Grd : _____ Vac	Phase L3 to Grd : _____ Vac	Phase L3 to Grd : <u>231.8</u> Vac	
	AC Line Current		AC Line Current	
	Phase L1 to Grd : _____ A	Phase L1 to Grd : _____ A	Phase L1 to Grd : _____ A	
	Phase L2 to Grd : _____ A	Phase L2 to Grd : _____ A	Phase L2 to Grd : _____ A	
	Phase L3 to Grd : _____ A	Phase L3 to Grd : _____ A	Phase L3 to Grd : _____ A	

Comment : _____

SMARTER ENERGY SOLUTION

Electrical Room Inspection



Customer Name :				Date :		
Solar Panel				Inverter		
Brand	Model	Capacity	Install	Brand	Model	S/N
		Kwp.	Panels			

Device	Ambient Temperature	Temperature				Remark
Inverter	42.8 C	Inside : 47.9 C	Outside : 44.3 C	Heatsync : 49.3 C		
AC Cabinet	36.4 C	MCB Breaker : 32 A.	RCCB Breaker : _____ A.	AC SPD : 3 Phase		
		AC Cable : 10 Sq.m.	Smart Meter : _____ C	CT Ratio : _____ A.		
		AC Terminal : 36.4 C	Phase Meter Ratio : _____ A.			
		String No.	DC Fuse	DC Breaker	DC SPD	MC4 Connector
DC Cabinet 1	36.5 C	String 1	36.8 C	36.8 C	36.7 C	37.9 C
			A.	Vdc A.	Vdc A.	
		String 2	36.1 C	36.7 C	36.4 C	38.2 C
			A.	Vdc A.	Vdc A.	
		String 3	_____ C	_____ C	_____ C	_____ C
			A.	Vdc A.	Vdc A.	
		String 4	_____ C	_____ C	_____ C	_____ C
			A.	Vdc A.	Vdc A.	
EE Room	37.1 C	AC Cable : 25 Sq.m.	Main Breaker : 100 A.	MCCB Feed : _____ A.		
		Wireway : 38.4 C	MDB / LC : 39.7 C	_____ C		

Comment : _____

Inspection By : _____

(Bunharn Libnoy)
Project Engineer

Date : ____/____/____

SMARTER ENERGY SOLUTION

Preventive Maintenance Solar System



Item	Solar System Inspection	Inspection		Remark
1	Clean the Solar panel (Use clean water) ทำความสะอาดแผงโซลาร์ เซลล์ (ใช้น้ำสะอาด)	☒ Pass	☐ Not Pass	
2	Check to see if the solar panel's condition ตรวจสอบการแตกร้าวของแผงโซลาร์ เซลล์	☒ Pass	☐ Not Pass	
3	Inspect the mounting points of the roof mounting support legs for the risk of water leaking. (Use water Proof , Polyurethane PU, Sika MultiSeal AP to prevent water leakage) ตรวจสอบจุดยึดของ Support ที่ยึดกับหลังคา ว่ามีจุดเสี่ยงที่จะทำให้เกิดน้ำรั่วได้หรือไม่ (ใช้ water proof , สิริโครน PU , แผ่นซีก้าป้องกันน้ำ)	☒ Pass	☐ Not Pass	
4	Inspect the mounting parts of the solar cell. ตรวจสอบสภาพโครงสร้างทั้งหมด เพื่อดูว่า PV, Mounting และอุปกรณ์ประกอบอื่นๆ ไม่หลวม	☒ Pass	☐ Not Pass	
5	Inspect the condition of all cables to make sure The cables does not sag down to the roof. ตรวจสอบสภาพของสายทั้งหมดเพื่อให้แน่ใจว่า สายไม่หย่อนลงไปที่หลังคา	☒ Pass	☐ Not Pass	
6	Inspect the tightness of the wire terminals. ตรวจสอบความแน่นของขั้วสายไฟ			
6.1	-AC - Grid in Inverter	☒ Pass	☐ Not Pass	
6.2	-Back - up in Inverter (Specific model Hybrid)	☒ Pass	☐ Not Pass	
6.3	-Battery (Specific model Hybrid)	☒ Pass	☐ Not Pass	
6.4	-AC Breaker	☒ Pass	☐ Not Pass	
6.5	-DC Breaker	☒ Pass	☐ Not Pass	
6.6	-Fuse Holder	☒ Pass	☐ Not Pass	
6.7	-Surge Protection	☒ Pass	☐ Not Pass	
6.8	- Smarter Meter & CT (Current Transformer)	☒ Pass	☐ Not Pass	
7	Check whether the SISO Switch is defective ตรวจสอบ SISO Switch ว่าชำรุดหรือไม่	☒ Pass	☐ Not Pass	
8	Inspect for malfunctions of the inverter and other related electrical equipment. ตรวจสอบความผิดปกติของอินเวอร์เตอร์และอุปกรณ์ไฟฟ้าอื่น ๆ ที่เกี่ยวข้อง	☒ Pass	☐ Not Pass	
9	Inspect heat of the solar panel whether there is an abnormal heat point or not (checked by using a thermal camera) การตรวจสอบความร้อนของแผงโซลาร์เซลล์ว่ามีจุดความร้อนผิดปกติหรือไม่ (ตรวจสอบโดยใช้กล้องถ่ายภาพความร้อน)	☒ Pass	☐ Not Pass	

Comment :

Inspection By :

(Bunharn Libnoy)
Project Engineer

Date : ____ / ____ / ____